

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

Building #	Building	Room #	Type	eACH	HEPA unit	HEPA Installed
1	University Hall	B130	CLASS	21.0	NO	
1	University Hall	122	CLASS	***	-	-
1	University Hall	312	CLASS	10.5	NO	
1	University Hall	B116	CLASS	7.7	NO	
1	University Hall	213	LECTURE	5.8	YES	YES
1	University Hall	112	CLASS	11.5	NO	
1	University Hall	103	CLASS	13.3	NO	
1	University Hall	102	CLASS	10.8	NO	
1	University Hall	101	CLASS	11.5	NO	
1	University Hall	B126/G	CLASS	9.9	NO	
2	Hamilton Hall	102	CLASS	2.6	YES	YES
2	Hamilton Hall	104	CLASS	6.5	NO	
2	Hamilton Hall	109	CLASS	10.6	NO	
2	Hamilton Hall	217	CLASS	7.9	NO	
2	Hamilton Hall	302	CLASS	20.2	NO	
2	Hamilton Hall	305	CLASS	4.9	YES	YES
2	Hamilton Hall	207	CLASS	10.8	NO	
2	Hamilton Hall	312	CLASS	12.0	NO	
2	Hamilton Hall	410	CLASS	14.8	NO	
9	NRB	B116	CLASS	11.9	NO	
9	NRB	B117	CLASS	4.1	YES	YES
10	Mills Library	L107	CLASS	4.7	YES	YES
10	Mills Library	L113	CLASS	10.4	NO	
11	Burke Science Building	104	CLASS	8.1	NO	
11	Burke Science Building	105	CLASS	10.5	NO	
11	Burke Science Building	106	CLASS	5.4	YES	YES
11	Burke Science Building	108	CLASS	6.7	NO	
11	Burke Science Building	115	CLASS	4.2	YES	YES
11	Burke Science Building	117	CLASS	4.7	YES	YES
11	Burke Science Building	119	CLASS	3.1	YES	YES
11	Burke Science Building	120	CLASS	4.4	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

11	Burke Science Building	121	CLASS	4.1	YES	YES
11	Burke Science Building	136	CLASS	10.8	NO	
11	Burke Science Building	137	CLASS	9.7	NO	
11	Burke Science Building	138	CLASS	8.5	NO	
11	Burke Science Building	147	LECTURE	12.7	NO	
11	Burke Science Building	201	CLASS	4.3	YES	YES
11	Burke Science Building	213	CLASS	7.1	NO	
11	Burke Science Building	214	CLASS	7.6	NO	
11	Burke Science Building	217	CLASS	6.5	NO	
11	Burke Science Building	218	CLASS	6.2	NO	
11	Burke Science Building	241	CLASS	9.5	NO	
11	Burke Science Building	244	CLASS	11.6	NO	
11	Burke Science Building	249	CLASS	7.5	NO	
11	Burke Science Building	315	CLASS	12.3	NO	
11	Burke Science Building	343	CLASS	12.7	NO	
11	Burke Science Building	345	CLASS	12.5	NO	
11	Burke Science Building	340A	CLASS	7.2	NO	
11	Burke Science Building	340B	CLASS	8.1	NO	
11	Burke Science Building	B101	CLASS	4.5	YES	YES
11	Burke Science Building	B102	CLASS	4.7	YES	YES
11	Burke Science Building	B103	CLASS	6.0	NO	
11	Burke Science Building	B110	CLASS	5.4	YES	YES
11	Burke Science Building	B115	CLASS	4.7	YES	YES
11	Burke Science Building	B116	CLASS	4.2	YES	YES
11	Burke Science Building	B132	CLASS	4.9	YES	YES
11	Burke Science Building	B135	CLASS	4.4	YES	YES
11	Burke Science Building	B136	CLASS	5.8	YES	YES
11	Burke Science Building	B138	CLASS	7.3	NO	
11	Burke Science Building	B140	CLASS	6.5	NO	
11	Burke Science Building	B142	CLASS	6.8	NO	
11	Burke Science Building	B154	CLASS	5.5	YES	YES
11	Burke Science Building	B155	CLASS	8.8	NO	
11	Burke Science Building	B156	CLASS	6.5	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

11	Burke Science Building	B157	CLASS	6.3	NO	
11	Burke Science Building	B203	CLASS	6.6	NO	
11	Burke Science Building	B205	CLASS	16.1	NO	
11	Burke Science Building	B206	CLASS	11.8	NO	
11	Burke Science Building	B220	CLASS	3.7	YES	YES
11	Burke Science Building	Room 238A	CLASS	5.6	YES	YES
11	Burke Science Building	B139	CLASS	5.0	YES	YES
11	Burke Science Building	Room 238	CLASS	5.3	YES	YES
11	Burke Science Building	117/A	CLASS	*	-	-
11	Burke Science Building	B119	CLASS	4.4	YES	YES
16	JHE	114	CLASS	11.7	NO	
16	JHE	128	CLASS	2.9	YES	YES
16	JHE	129	CLASS	7.6	NO	
16	JHE	134	CLASS	5.3	YES	YES
16	JHE	210	CLASS	1.3	YES	YES
16	JHE	239	CLASS	5.5	YES	YES
16	JHE	240	CLASS	7.5	NO	
16	JHE	241	CLASS	9.3	NO	
16	JHE	242	CLASS	18.9	NO	
16	JHE	244	CLASS	5.9	YES	YES
16	JHE	245	CLASS	3.9	YES	YES
16	JHE	246	CLASS	4.7	YES	YES
16	JHE	248	CLASS	2.3	YES	YES
16	JHE	329	CLASS	5.6	YES	YES
16	JHE	351	CLASS	22.9	NO	
16	JHE	376	CLASS	20.0	NO	
16	JHE	246/A	CLASS	3.5	YES	YES
16	JHE	246A	CLASS	****	YES	YES
16	JHE	326H	CLASS	3.0	YES	YES
16	JHE	A102	CLASS	8.2	NO	
16	JHE	A106	CLASS	3.1	YES	YES
16	JHE	A303B	CLASS	5.5	YES	YES
16	JHE	A303F	CLASS	4.1	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

16	JHE	A304	CLASS	****	YES	YES
16	JHE	B131	CLASS	4.6	YES	YES
16	JHE	A101	CLASS	11.3	NO	
16	JHE	144	CLASS	4.0	YES	YES
16	JHE	323	CLASS	1.1	YES	YES
16	JHE	131	CLASS	****	YES	YES
16	JHE	264	CLASS	17.6	NO	
16	JHE	132	CLASS	10.1	NO	
16	JHE	233A	CLASS	3.7	YES	YES
16	JHE	342	CLASS	12.4	NO	
16	JHE	332	CLASS	1.7	YES	YES
17	Divinity College	136	CLASS	9.2	NO	
17	Divinity College	141	CLASS	4.0	YES	YES
17	Divinity College	226	CLASS	5.4	YES	YES
17	Divinity College	231	CLASS	11.5	NO	
17	Divinity College	144	CLASS	9.0	NO	
20	Gilmour Hall	111	CLASS	15.1	NO	
20	Gilmour Hall	111/A	LECTURE	5.6	YES	YES
22	General Sciences	116	CLASS	8.7	NO	
22	General Sciences	329	CLASS	0.4	YES	YES
22	General Sciences	102	CLASS	14.9	NO	
22	General Sciences	101	CLASS	14.9	NO	
23	CNH	102	CLASS	8.9	NO	
23	CNH	104	LECTURE	12.3	NO	
23	CNH	106	CLASS	11.4	NO	
23	CNH	223	CLASS	5.5	YES	YES
23	CNH	332	CLASS	4.9	YES	YES
23	CNH	607	CLASS	59.8	NO	
23	CNH	607B	CLASS	4.0	YES	YES
23	CNH	B107	CLASS	12.2	NO	
23	CNH	103	LECTURE	6.0	YES	YES
23	CNH	207	CLASS	6.7	NO	
23	CNH	307	CLASS	6.2	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

23	CNH	407	CLASS	4.3	YES	YES
23	CNH	217	CLASS	6.0	YES	YES
23	CNH	317	CLASS	6.5	NO	
24	Ivor Wynne Centre	223	CLASS	18.9	NO	
24	Ivor Wynne Centre	224	CLASS	9.7	NO	
24	Ivor Wynne Centre	A102G	CLASS	3.9	YES	YES
24	Ivor Wynne Centre	A102K	CLASS	3.1	YES	YES
24	Ivor Wynne Centre	E201	CLASS	11.5	NO	
24	Ivor Wynne Centre	201	CLASS	12.4	NO	
24	Ivor Wynne Centre	218	CLASS	16.2	NO	
24	Ivor Wynne Centre	220	CLASS	7.6	NO	
25	ABB	102	CLASS	7.1	NO	
25	ABB	106	CLASS	4.9	YES	YES
25	ABB	122	LECTURE	17.6	NO	
25	ABB	136	CLASS	5.2	YES	YES
25	ABB	162	CLASS	6.7	NO	
25	ABB	163	CLASS	13.0	NO	
25	ABB	164	CLASS	12.7	NO	
25	ABB	165	CLASS	9.1	NO	
25	ABB	166	CLASS	13.7	NO	
25	ABB	217	LECTURE	12.3	NO	
25	ABB	270	CLASS	7.9	NO	
25	ABB	271	CLASS	13.9	NO	
25	ABB	302	LECTURE	21.6	NO	
25	ABB	319	CLASS	3.6	YES	YES
25	ABB	402	LECTURE	17.5	NO	
25	ABB	A404	CLASS	5.5	YES	YES
25	ABB	B118	CLASS	9.5	NO	
25	ABB	C103	CLASS	6.4	NO	
25	ABB	C104	CLASS	5.6	YES	YES
25	ABB	C202	CLASS	12.4	NO	
25	ABB	C207	CLASS	13.2	NO	
25	ABB	C208	CLASS	6.7	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

25	ABB	307	CLASS	3.2	YES	YES
29	Togo Salmon Hall	104	CLASS	9.3	NO	
29	Togo Salmon Hall	114	CLASS	4.0	YES	YES
29	Togo Salmon Hall	118	CLASS	6.0	NO	
29	Togo Salmon Hall	122	CLASS	19.4	NO	
29	Togo Salmon Hall	201	CLASS	1.6	YES	YES
29	Togo Salmon Hall	203	CLASS	1.7	YES	YES
29	Togo Salmon Hall	206	CLASS	1.9	YES	YES
29	Togo Salmon Hall	321	CLASS	3.1	YES	YES
29	Togo Salmon Hall	402	CLASS	2.9	YES	YES
29	Togo Salmon Hall	701	CLASS	3.0	YES	YES
29	Togo Salmon Hall	202B*	CLASS	10.6	NO	
29	Togo Salmon Hall	B102	CLASS	12.3	NO	
29	Togo Salmon Hall	B103	LECTURE	1.7	YES	YES
29	Togo Salmon Hall	B105	CLASS	11.3	NO	
29	Togo Salmon Hall	B106	CLASS	7.8	NO	
29	Togo Salmon Hall	B124	CLASS	4.5	YES	YES
29	Togo Salmon Hall	B126	CLASS	6.7	NO	
29	Togo Salmon Hall	B128	CLASS	10.2	NO	
29	Togo Salmon Hall	B129	CLASS	7.6	NO	
29	Togo Salmon Hall	324	CLASS	3.6	YES	YES
29	Togo Salmon Hall	421	CLASS	4.6	YES	YES
29	Togo Salmon Hall	423	CLASS	5.8	YES	YES
29	Togo Salmon Hall	424	CLASS	4.1	YES	YES
29	Togo Salmon Hall	501	CLASS	3.5	YES	YES
29	Togo Salmon Hall	621	CLASS	3.4	YES	YES
29	Togo Salmon Hall	712	CLASS	5.2	YES	YES
29	Togo Salmon Hall	512	CLASS	5.9	YES	YES
29	Togo Salmon Hall	530	CLASS	2.7	YES	YES
29	Togo Salmon Hall	B107	CLASS	3.4	YES	YES
29	Togo Salmon Hall	B108	CLASS	7.9	NO	
29	Togo Salmon Hall	120	LECTURE	5.0	YES	YES
34	PSYCH	155	CLASS	11.0	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

34	PSYCH	237	CLASS	8.6	NO	
34	PSYCH	335	CLASS	10.6	NO	
34	PSYCH	311	CLASS	4.3	YES	YES
34	PSYCH	316	CLASS	3.2	YES	YES
34	PSYCH	154	CLASS	25.8	NO	
34	PSYCH	204	CLASS	5.7	YES	YES
38	KTH	104	CLASS	6.5	NO	
38	KTH	105	CLASS	8.9	NO	
38	KTH	106	CLASS	8.7	NO	
38	KTH	107	CLASS	9.3	NO	
38	KTH	109	CLASS	10.0	NO	
38	KTH	308	CLASS	17.2	NO	
38	KTH	B101	CLASS	5.3	YES	YES
38	KTH	B103	CLASS	7.9	NO	
38	KTH	B104	CLASS	6.2	NO	
38	KTH	B105	CLASS	7.3	NO	
38	KTH	B107	CLASS	8.4	NO	
38	KTH	B121	CLASS	29.7	NO	
38	KTH	B123	CLASS	29.1	NO	
38	KTH	B124	CLASS	7.3	NO	
38	KTH	B132	CLASS	4.3	YES	YES
38	KTH	B135	CLASS	6.9	NO	
38	KTH	B102	CLASS	6.8	NO	
38	KTH	B108	CLASS	7.5	NO	
38	KTH	306	CLASS	14.7	NO	
38	KTH	503	CLASS	19.5	NO	
38	KTH	709	CLASS	22.5	NO	
38	KTH	712	CLASS	20.2	NO	
38	KTH	732	CLASS	20.8	NO	
38	KTH	306A	CLASS	19.6	NO	
38	KTH	B122	CLASS	4.3	YES	YES
38	KTH	Room 227A	CLASS	11.9	NO	
38	KTH	334	CLASS	5.3	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

39	Life Sciences	107	CLASS	5.2	YES	YES
39	Life Sciences	108	CLASS	4.4	YES	YES
39	Life Sciences	109	CLASS	4.4	YES	YES
39	Life Sciences	110	CLASS	3.2	YES	YES
39	Life Sciences Building	B130/E	CLASS	11.7	NO	
43	CRL	B119	CLASS	5.0	YES	YES
46	Degroote School of Business	AB102	CLASS	9.3	NO	
46	Degroote School of Business	AB103	CLASS	9.8	NO	
46	Degroote School of Business	B105	CLASS	8.2	NO	
46	Degroote School of Business	B107	CLASS	7.4	NO	
46	Degroote School of Business	505	CLASS	8.8	NO	
46	Degroote School of Business	B106	CLASS	3.8	YES	YES
48	IAHS	451	CLASS	2.8	YES	YES
48	IAHS	103B	CLASS	7.8	NO	
48	IAHS	B114	CLASS	2.7	YES	YES
48	IAHS	105	CLASS	5.4	YES	YES
48	IAHS	138	CLASS	6.0	YES	YES
48	IAHS	139	CLASS	3.1	YES	YES
48	IAHS	141	CLASS	6.2	NO	
48	IAHS	142	CLASS	4.1	YES	YES
48	IAHS	143	CLASS	2.7	YES	YES
48	IAHS	144	CLASS	7.0	NO	
48	IAHS	144	CLASS	5.0	YES	YES
48	IAHS	145	CLASS	7.4	NO	
48	IAHS	146	CLASS	4.8	YES	YES
48	IAHS	148	CLASS	7.9	NO	
48	IAHS	220	CLASS	4.2	YES	YES
48	IAHS	238	CLASS	6.1	NO	
48	IAHS	239	CLASS	5.9	YES	YES
48	IAHS	240	CLASS	5.2	YES	YES
48	IAHS	241	CLASS	4.0	YES	YES
48	IAHS	242	CLASS	5.3	YES	YES
48	IAHS	243	CLASS	5.7	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

48	IAHS	244	CLASS	5.0	YES	YES
48	IAHS	245	CLASS	3.9	YES	YES
48	IAHS	246	CLASS	8.9	NO	
48	IAHS	249	CLASS	3.8	YES	YES
48	IAHS	301	CLASS	5.2	YES	YES
48	IAHS	357	CLASS	5.1	YES	YES
48	IAHS	358	CLASS	5.5	YES	YES
48	IAHS	359	CLASS	3.1	YES	YES
48	IAHS	360	CLASS	3.6	YES	YES
48	IAHS	361	CLASS	3.9	YES	YES
48	IAHS	362	CLASS	5.7	YES	YES
48	IAHS	363	CLASS	5.6	YES	YES
48	IAHS	364	CLASS	6.2	NO	
48	IAHS	365	CLASS	14.0	NO	
48	IAHS	366	CLASS	8.5	NO	
48	IAHS	367	CLASS	3.2	YES	YES
48	IAHS	454	CLASS	5.9	YES	YES
48	IAHS	455	CLASS	6.4	NO	
48	IAHS	457	CLASS	7.1	NO	
48	IAHS	458	CLASS	6.4	NO	
48	IAHS	461	CLASS	9.2	NO	
48	IAHS	243A	CLASS	5.1	YES	YES
48	IAHS	304/A/B/C	CLASS	4.5	YES	YES
48	IAHS	359A	CLASS	3.2	YES	YES
48	IAHS	405/B	CLASS	3.5	YES	YES
48	IAHS	434A	CLASS	2.4	YES	YES
48	IAHS	440/A	CLASS	2.6	YES	YES
48	IAHS	452/A	CLASS	2.7	YES	YES
48	IAHS	B102	CLASS	4.8	YES	YES
48	IAHS	B109	CLASS	5.5	YES	YES
48	IAHS	103A	CLASS	12.0	NO	
48	IAHS	104D	CLASS	5.3	YES	YES
48	IAHS	104E	CLASS	4.3	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

48	IAHS	104F	CLASS	3.1	YES	YES
48	IAHS	201	CLASS	5.1	YES	YES
48	IAHS	201A	CLASS	3.7	YES	YES
48	IAHS	203	CLASS	7.0	NO	
48	IAHS	203A	CLASS	4.5	YES	YES
48	IAHS	203B	CLASS	4.3	YES	YES
48	IAHS	205A	CLASS	3.6	YES	YES
48	IAHS	205B	CLASS	5.5	YES	YES
48	IAHS	205C	CLASS	6.0	YES	YES
48	IAHS	205D	CLASS	9.5	NO	
48	IAHS	205E	CLASS	9.9	NO	
48	IAHS	205F	CLASS	7.9	NO	
48	IAHS	205I	CLASS	10.0	NO	
48	IAHS	205J	CLASS	5.1	YES	YES
48	IAHS	205K	CLASS	2.8	YES	YES
48	IAHS	205L	CLASS	3.3	YES	YES
48	IAHS	208	CLASS	7.6	NO	
48	IAHS	303	CLASS	4.5	YES	YES
48	IAHS	460	CLASS	4.1	YES	YES
48	IAHS	Library	CLASS	5.6	YES	YES
49	ITB	137	LECTURE	5.7	YES	YES
49	ITB	139	CLASS	4.4	YES	YES
49	ITB	155	CLASS	10.2	NO	
49	ITB	235	CLASS	1.7	YES	YES
49	ITB	236	CLASS	7.4	NO	
49	ITB	237	CLASS	1.4	YES	YES
49	ITB	238	CLASS	7.2	NO	
49	ITB	AB102	CLASS	12.0	NO	
49	ITB	222	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	1110	LECTURE	6.2	NO	
52	M.G.D. Centre For Learning	3022	CLASS	6.2	NO	
52	M.G.D. Centre For Learning	3504	CLASS	6.3	NO	
52	M.G.D. Centre For Learning	Room 1008	CLASS	8.0	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

52	M.G.D. Centre For Learning	Room 1009	CLASS	7.3	NO	
52	M.G.D. Centre For Learning	Room 1010	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 1016	CLASS	5.2	YES	YES
52	M.G.D. Centre For Learning	Room 1102	LECTURE	3.7	YES	YES
52	M.G.D. Centre For Learning	Room 1105	LECTURE	5.0	YES	YES
52	M.G.D. Centre For Learning	Room 1309	LECTURE	4.7	YES	YES
52	M.G.D. Centre For Learning	Room 2233	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 3017	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 3019	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 3023	CLASS	3.8	YES	YES
52	M.G.D. Centre For Learning	Room 3024	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 3413	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 1115	CLASS	13.1	NO	
52	M.G.D. Centre For Learning	Room 1116	CLASS	12.9	NO	
52	M.G.D. Centre For Learning	Room 1305	LECTURE	4.3	YES	YES
52	M.G.D. Centre For Learning	3010	CLASS	5.9	YES	YES
52	M.G.D. Centre For Learning	3502	CLASS	11.4	NO	
52	M.G.D. Centre For Learning	3503	CLASS	9.0	NO	
52	M.G.D. Centre For Learning	3505	CLASS	14.6	NO	
52	M.G.D. Centre For Learning	3010A	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	3412	CLASS	3.8	YES	YES
52	M.G.D. Centre For Learning	3300/B	CLASS	8.9	NO	
52	M.G.D. Centre For Learning	Room 1307	LECTURE	3.8	YES	YES
52	M.G.D. Centre For Learning	Room 2218	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 2221	CLASS	5.0	YES	YES
52	M.G.D. Centre For Learning	Room 2225	CLASS	3.2	YES	YES
52	M.G.D. Centre For Learning	Room 2225A	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 2230	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 2232	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 2242	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 2243	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 2244	CLASS	6.2	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

52	M.G.D. Centre For Learning	Room 2245	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 2246	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 2247	CLASS	6.2	NO	
52	M.G.D. Centre For Learning	Room 2248	CLASS	6.8	NO	
52	M.G.D. Centre For Learning	Room 2249	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 3012	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 3013	CLASS	6.0	NO	
52	M.G.D. Centre For Learning	Room 3015	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 3016	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 3018	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 3020	CLASS	6.1	NO	
52	M.G.D. Centre For Learning	Room 3300/B	CLASS	11.1	NO	
52	M.G.D. Centre For Learning	Room 3410	CLASS	6.2	NO	
52	M.G.D. Centre For Learning	Room 3411	CLASS	6.0	NO	
56	ETB	119	CLASS	4.9	YES	YES
56	ETB	125	CLASS	3.8	YES	YES
56	ETB	224	CLASS	2.4	YES	YES
56	ETB	227	CLASS	2.4	YES	YES
56	ETB	228	CLASS	7.8	NO	
56	ETB	230	CLASS	4.9	YES	YES
56	ETB	235	CLASS	8.9	NO	
56	ETB	237	CLASS	7.9	NO	
56	ETB	238	CLASS	8.8	NO	
56	ETB	311	CLASS	14.9	NO	
56	ETB	534	CLASS	5.2	YES	YES
56	ETB	537	CLASS	5.5	YES	YES
56	ETB	B103	CLASS	3.5	YES	YES
56	ETB	B111	CLASS	3.1	YES	YES
56	ETB	121	CLASS	2.8	YES	YES
56	ETB	122	CLASS	4.7	YES	YES
56	ETB	124	CLASS	16.1	NO	
56	ETB	126	CLASS	5.0	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

56	ETB	234	CLASS	2.9	YES	YES
56	ETB	236	CLASS	8.6	NO	
56	ETB	239	CLASS	8.6	NO	
56	ETB	535	CLASS	4.0	YES	YES
74	LR Wilson	1048	LECTURE	2.6	YES	YES
74	LR Wilson	1055	CLASS	7.9	NO	
74	LR Wilson	1056	CLASS	9.5	NO	
74	LR Wilson	1057	CLASS	8.3	NO	
74	LR Wilson	2001	CLASS	5.3	YES	YES
74	LR Wilson	4001	CLASS	9.6	NO	
74	LR Wilson	5012	CLASS	10.5	NO	
74	LR Wilson	B1006	CLASS	10.6	NO	
74	LR Wilson	B1007	LECTURE	5.4	YES	YES
74	LR Wilson	1003	CLASS	5.8	YES	YES
74	LR Wilson	3001	CLASS	9.0	NO	
74	LR Wilson	5001	CLASS	6.9	NO	
74	LR Wilson	2012	CLASS	6.4	NO	
74	LR Wilson	3017	CLASS	10.6	NO	
89	PGCLL	124	CLASS	5.9	YES	YES
89	PGCLL	127	LECTURE	4.9	YES	YES
89	PGCLL	B131	CLASS	4.6	YES	YES
89	PGCLL	M12	CLASS	4.7	YES	YES
89	PGCLL	M16	CLASS	5.3	YES	YES
89	PGCLL	M21	LECTURE	5.0	YES	YES
89	PGCLL	M22	CLASS	4.1	YES	YES
89	PGCLL	M24	CLASS	4.5	YES	YES
89	PGCLL	M25	CLASS	4.4	YES	YES
89	PGCLL	B138	LECTURE	10.1	NO	
89	PGCLL	M04	CLASS	5.2	YES	YES
89	PGCLL	M26	CLASS	4.1	YES	YES
T13	Temporary Building 13	105	CLASS	9.6	NO	
T13	Temporary Building 13	125	CLASS	5.2	YES	YES
T13	Temporary Building 13	127	CLASS	1.8	YES	YES

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct

CLASSROOM AND LECTURE HALL LIST (Updated: January 28, 2022)

T13	Temporary Building 13	106	CLASS	8.6	NO	
T13	Temporary Building 13	107	CLASS	5.7	YES	YES
T13	Temporary Building 13	123	LECTURE	7.4	NO	
T34	Temporary Building 34	103	CLASS	8.9	NO	
T34	Temporary Building 34	104	CLASS	7.8	NO	

Notes:

1. All classrooms/lecture halls to meet 6 eACH. Classrooms/lecture halls not meeting 6 eACH will have stand-alone filtration (HEPA) units installed, to meet the 6 eACH target

*Room is under construction

**Due to the size of LR Wilson 1048, eACH has not been calculated for this space. The ventilation was verified and deemed adequate based on design.

***University Hall Room 122 has been taken offline.

****Rooms have no supply air but has exhaust or a small transfer air duct